



ANALYTICAL RESULTS

Workorder: 358926 WYANDOTTE 2-120619

Lab ID: 3589260001 Date Received: 12/6/2019 15:07 Matrix: Drinking Water (Potable)
 Sample ID: Raw Water Date Collected: 12/6/2019 13:00
 Sample Desc: WSSN: 7210, Filter Plant PO:

Parameters	Qualifier	Result	Units	Reporting Limit	Dilution Factor	Result Qualifier		Analyzed	By
						Min	Max		
Metals									
Analysis Desc: EPA 245.1									
Mercury, Total		<0.00020	mg/L	0.00020	1		0.002	12/11/2019 12:08	RLC
Analysis Desc: EPA 200.8									
Antimony, Total		<0.0010	mg/L	0.0010	1		0.006	12/12/2019 13:52	MKK
Arsenic, Total		0.0011	mg/L	0.0010	1		0.01	12/12/2019 13:52	MKK
Barium, Total		0.016	mg/L	0.0050	1		2	12/12/2019 13:52	MKK
Beryllium, Total		<0.00040	mg/L	0.00040	1		0.004	12/12/2019 13:52	MKK
Cadmium, Total		<0.00020	mg/L	0.00020	1		0.005	12/12/2019 13:52	MKK
Chromium, Total		<0.0010	mg/L	0.0010	1		0.1	12/12/2019 13:52	MKK
Lead, Total		<0.0010	mg/L	0.0010	1		0.015	12/12/2019 13:52	MKK
Nickel, Total		0.0017	mg/L	0.0010	1			12/12/2019 13:52	MKK
Selenium, Total		<0.0010	mg/L	0.0010	1		0.05	12/12/2019 13:52	MKK
Thallium, Total		<0.00040	mg/L	0.00040	1		0.002	12/12/2019 13:52	MKK

MCL

MCL - Maximum Contaminant Levels for Drinking Water

Paragon Laboratories, Inc. is certified by the Michigan DEQ to analyze Drinking Water. (MDEQ Lab No. 9901 Expires 2/25/2020)
 This report shall not be reproduced, except in full, without the written consent of Paragon Laboratories, Inc..



ANALYTICAL RESULTS

Workorder: 358983 WYANDOTTE 2-121019

Lab ID: **3589830002** Date Received: 12/10/2019 14:48 Matrix: Drinking Water (Potable)
 Sample ID: RAW Date Collected: 12/10/2019 13:45
 Sample Desc: WSSN: 7210, Grab PO:

Parameters	Qualifier	Result	Units	Reporting Limit	Dilution Factor	Result Qualifier		Analyzed	By
						Min	Max		
Metals									
Analysis Desc: EPA 245.1									
Mercury, Total		<0.00020	mg/L	0.00020	1		0.002	12/12/2019 09:32	MKK
Analysis Desc: EPA 200.8									
Cadmium, Total		<0.00020	mg/L	0.00020	1		0.005	12/12/2019 13:50	MKK
Chromium, Total		<0.0010	mg/L	0.0010	1		0.1	12/12/2019 13:50	MKK
Copper, Total		0.0071	mg/L	0.0010	1		1.3	12/12/2019 13:50	MKK
Lead, Total		<0.0010	mg/L	0.0010	1		0.015	12/12/2019 13:50	MKK
Nickel, Total		0.0016	mg/L	0.0010	1			12/12/2019 13:50	MKK
Silver, Total		<0.00020	mg/L	0.00020	1		0.1	12/12/2019 13:50	MKK
Zinc, Total		0.0056	mg/L	0.0040	1		5	12/12/2019 13:50	MKK
Analysis Desc: EPA 200.7									
Iron, Total		0.17	mg/L	0.10	1		0.3	12/12/2019 12:16	MKK
Sample Preparation									
Analysis Desc: EPA 525.2									
Liquid-Solid Extr. Pests+Inds		Complete			1			12/11/2019 07:45	RLC
SOC Pesticides and Industrials									
Analysis Desc: EPA 525.2									
Benzo(a)pyrene		<0.050	µg/L	0.050	1		200	12/11/2019 12:59	DTM
PCB Aroclor 1016		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:59	DTM
PCB Aroclor 1221		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:59	DTM
PCB Aroclor 1232		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:59	DTM
PCB Aroclor 1242		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:59	DTM
PCB Aroclor 1248		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:59	DTM
PCB Aroclor 1254		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:59	DTM
PCB Aroclor 1260		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:59	DTM

MCL

Paragon Laboratories, Inc. is certified by the Michigan DEQ to analyze Drinking Water. (MDEQ Lab No. 9901 Expires 2/25/2020)
 This report shall not be reproduced, except in full, without the written consent of Paragon Laboratories, Inc..



ANALYTICAL RESULTS

Workorder: 358983 WYANDOTTE 2-121019

Lab ID: **3589830001** Date Received: 12/10/2019 14:48 Matrix: Drinking Water (Potable)
 Sample ID: TAP Date Collected: 12/10/2019 13:45
 Sample Desc: WSSN: 7210, Grab PO:

Parameters	Qualifier	Result	Units	Reporting Limit	Dilution Factor	Result Qualifier		Analyzed	By
						Min	Max		
Metals									
Analysis Desc: EPA 245.1									
Mercury, Total		<0.00020	mg/L	0.00020	1		0.002	12/12/2019 09:32	MKK
Analysis Desc: EPA 200.8									
Cadmium, Total		<0.00020	mg/L	0.00020	1		0.005	12/12/2019 13:15	MKK
Chromium, Total		0.0011	mg/L	0.0010	1		0.1	12/12/2019 13:15	MKK
Copper, Total		0.0021	mg/L	0.0010	1		1.3	12/12/2019 13:15	MKK
Lead, Total		<0.0010	mg/L	0.0010	1		0.015	12/12/2019 13:15	MKK
Nickel, Total		0.0018	mg/L	0.0010	1			12/12/2019 13:15	MKK
Silver, Total		<0.00020	mg/L	0.00020	1		0.1	12/12/2019 13:15	MKK
Zinc, Total		<0.0040	mg/L	0.0040	1		5	12/12/2019 13:15	MKK
Analysis Desc: EPA 200.7									
Iron, Total		<0.10	mg/L	0.10	1		0.3	12/12/2019 08:47	MKK
Sample Preparation									
Analysis Desc: EPA 525.2									
Liquid-Solid Extr. Pests+Inds		Complete			1			12/11/2019 07:45	RLC
SOC Pesticides and Industrials									
Analysis Desc: EPA 525.2									
Benzo(a)pyrene		<0.050	µg/L	0.050	1		200	12/11/2019 12:22	DTM
PCB Aroclor 1016		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:22	DTM
PCB Aroclor 1221		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:22	DTM
PCB Aroclor 1232		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:22	DTM
PCB Aroclor 1242		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:22	DTM
PCB Aroclor 1248		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:22	DTM
PCB Aroclor 1254		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:22	DTM
PCB Aroclor 1260		<0.10	µg/L	0.10	1		0.5	12/11/2019 12:22	DTM

MCL

Paragon Laboratories, Inc. is certified by the Michigan DEQ to analyze Drinking Water. (MDEQ Lab No. 9901 Expires 2/25/2020)
 This report shall not be reproduced, except in full, without the written consent of Paragon Laboratories, Inc..